

TEST REPORT



Your Ref:

Date: 01 Sep 2004

Our Ref: 55S041361/A/HSW/JT

Page: 1 of 5

DID: 6885 1372

Fax: 6776 1568

NOTE: This report is issued subject to PSB Corporation's "Terms and Conditions Governing Technical Services". The terms and conditions governing the issue of this report are set out as attached within this report.

Subject

TYPE TESTING OF CONDUIT FITTINGS

Client

Litaflex Plastics Manufacturing Pte Ltd
10 Senoko Drive
Singapore 758198

Attn: Mr Alex Tan

Sample Submission Date

11 Jun 2004 & 30 Aug 2004

Description of Sample

Trademark	:	LITAFLEX
Model	:	PLCPC 204 (Four way circular conduit fitting)
Nominal size	:	20mm
Quantity	:	12 pieces
Manufacturer	:	Litaflex Plastics Manufacturing Pte Ltd
Country of origin	:	Singapore



Our Ref: 55S041361/A/HSW/JT

Method of Test

The assessment detailed in this document was carried out in accordance with British Standard 4607 : Part 5 : 1982 "Specification for rigid conduits, fittings and components of insulating material" with amendment nos. 1 & 2.

Results

Clause No	Title	Results
2	General requirements	
2.2	Preferred dimensions	Complied
3	Generation conditions for tests	Complied
4	Classification	
	Maximum working temperature	60°C
	Suspended load	3 Kg
5	Marking	Complied
6	Construction	
6.1	Made of insulating material	Complied
6.2	Smooth and free from burrs	Complied
6.3	Conduits entries of fittings and components	Complied
6.4	Screws used shall not cause damage to cable insulation	Complied
6.5	Lugs and fixing threads have adequate mechanical strength	Complied
7	Mechanical properties of fittings and components	
7.2	Suspended load test	Complied
7.3	Safety on impact test	Complied
8	Resistance to heat	
8.2	Ball-pressure test	Complied
9	Resistance to burning	
9.2	Burning test	Complied
10	Insulating characteristics	
10.4	Electrical insulating strength test	Complied
10.5	Insulation resistance test	Complied


Our Ref: 55S041361/A/HSW/JT

Remarks:

- 1) The conduit fittings were submitted for type testing.
- 2) The test results were based on testing of 12 pieces of LITAFLEX model PLCPC 204 (Four way circular conduit fitting) supplied by the client.
- 3) The conduit fittings submitted are deemed to comply with British Standard 4607 : Part 5 : 1982 with amendment nos. 1 and 2.



**HO SHUE WEE
TESTING OFFICER**




**JIMMY TAN
PRODUCT MANAGER
HOME APPLIANCES & CABLES
PSB TESTING**

Our Ref: 55S041361/A/HSW/JT

Appendix I

General view and marking on the Four way circular conduit fitting



This Report is issued under the following conditions:

1. Results of the testing/calibration in the form of a report will be issued immediately after the service has been completed or terminated.
2. Unless otherwise requested, a report shall contain only technical results. Analysis and interpretation of the results and professional opinion and recommendations expressed thereupon, if required, shall be clearly indicated and additional fee paid for, by the Client.
3. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that PSB Corporation approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that PSB Corporation in any way "guarantees" the later performance of the product/equipment.
4. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. PSB Corporation therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
5. Additional copies of the report are available to the Client at an additional fee. No third party can obtain a copy of this report through PSB Corporation, unless the Client has authorised PSB Corporation in writing to do so.
6. PSB Corporation may at its sole discretion add to or amend the conditions of the report at the time of issue of the report and such report and such additions or amendments shall be binding on the Client.
7. All copyright in the report shall remain with PSB Corporation and the Client shall, upon payment of PSB Corporation's fees for the carrying out of the tests/calibrations, be granted a license to use or publish the report to the third parties subject to the terms and conditions herein, provided always that PSB Corporation may at its absolute discretion be entitled to impose such conditions on the license as it sees fit.
8. Nothing in this report shall be interpreted to mean that PSB Corporation has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
9. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to PSB Corporation or to the report or results furnished by PSB Corporation in any advertisements or sales promotion.
10. Unless otherwise stated, the tests are carried out in PSB Corporation Pte Ltd, No.1 Science Park Drive Singapore 118221.

June 2004